



Defense Commissary Agency's Experience with Transcritical Carbon Dioxide

October 27, 2020

Questions and Webinar Feedback




Question and Answer Session

- Participants are muted
- Questions will be moderated at the end
- To ask a question, enter your comment into the chat box

Feedback Form

- We value your input!
- The link to a feedback form will appear in the chat window



Webinar Materials



Recording and Slides

- Webinar is being recorded
- Materials will be posted on the GreenChill website under Events and Webinars: www.epa.gov/greenchill
- To receive notification when materials are posted email: EPA-GreenChill@abtassoc.com

Program Overview




GreenChill is a voluntary partnership program that works collaboratively with the food retail industry to reduce refrigerant emission and decrease stores' impact on the ozone layer and climate system

GreenChill works to help food retailers:

- Lower refrigerant charge sizes and eliminate leaks
- Transition to environmentally friendlier refrigerants
- Adopt green refrigeration technologies and best environmental practices

www.epa.gov/greenchill



2020 Ozone Layer Protection Milestones



In March 2020, EPA published a new site to highlight achievements made possible because of the Clean Air Act Title VI - Stratospheric Ozone Protection

The screenshot shows the EPA website's navigation bar with links for "Environmental Topics", "Laws & Regulations", and "About EPA", along with a search bar. The main heading is "Ozone Layer Protection Milestones of the Clean Air Act". Below this is a featured article for "Strat City, USA" with a colorful 3D cityscape illustration. To the right of the illustration is a text box that says: "Throughout 2020 we will be highlighting the many achievements made possible because of the Clean Air Act Title VI - Stratospheric Ozone Protection. From Discovery to Recovery: Follow our highlights for in-depth information on how we protect the stratospheric ozone layer." Below the illustration is an "Overview" section with text: "2020 is a milestone year for ozone layer protection in the United States. In the thirty years since Congress amended the Clean Air Act (CAA) to add Title VI: Stratospheric Ozone Protection, EPA has worked with many partners to develop and implement flexible, innovative, and effective approaches to phase out ozone-depleting substances (ODS) and heal the ozone layer. By restoring the ozone layer, we reduce the risks of skin cancer and cataracts. Ozone-depleting substances have been used in many household, industrial, and military applications. In response to significant concern for our ozone layer, through the Montreal Protocol and CAA Title VI, the United States has been substituting ODS with safer alternatives. At the same time, global demand for refrigeration and cooling technologies continues to expand. Most transitions to safer alternatives have been seamless for consumers who use these products in their daily lives. Today, we see signs that the ozone layer is healing. For Americans, full implementation of the Montreal Protocol is expected to result in the prevention of no less than 280 million cases of skin cancer and at least 45 million cases of cataracts in the United States alone. This remarkable success is due to the important and cooperative achievements that continue to be made by people, programs, and organizations working together to protect the Earth's ozone layer."


www.epa.gov/ozone-layer-protection-milestones-clean-air-act

Strat City, USA



An interactive webpage where users can explore how ozone layer protection affects many aspects of everyday life.

GreenChill is highlighted



Learn More



www.linkedin.com/groups/1426947/

www.epa.gov/greenchill

GreenChill@epa.gov



Today's speakers...

John Stuit



John Stuit

Chief, Defense Commissary Agency

Design & Construction

Phone: 804-894-1738

Email: john.stuit@deca.mil



John Stuit brings 34 years of experience to the supermarket industry. As Chief of Design and Construction, he executes the global design and construction program for DeCA. He is also a certified Construction Manager and has a strong interest in emerging technologies for refrigeration systems. He has a Bachelor's of Science in Mechanical Engineering.

Abtar Singh



Abtar Singh

President, Singh360, Inc.

Phone: 651-605-1093

Email: abtar@singh360.com



Abtar Singh is the President of Singh360, Inc. He specializes in facility management systems, performance monitoring, predictive analytics, and optimization of energy and maintenance systems. He previously served as the Vice President of Product Management and Engineering at Emerson Climate Technologies and was the Vice President of Business Development for Verisae. He holds a Bachelor's of Science in Energy Engineering from the Indian Institute of Technology in Kharagpur, India and a Master's Degree and Doctorate in Mechanical Engineering from the University of Maryland in College Park.

What Is DeCA?



The Defense Commissary Agency (DeCA) is the supermarket to the military.

- 236 stores world wide on military bases
- Cold storage and distribution facilities overseas
- \$5 billion in grocery sales
- Retail organization looking at what the future holds and planning for it

Locations of CO₂ Systems



Location

- Spangdahlem, Germany
- Lakenheath, England
- Vicenza, Italy
- Lackland Air Force Base (AFB)
(San Antonio, TX)
- Newport, RI
- Vandenburg AFB, California
- Edwards AFB, CA (Mojave, CA)
- Mountain Home, ID

Climate

Cool

Cool

Warm & Dry

Hot & Humid

Marine

Marine

Hot & Dry

Mountain

Low Charge Micro-distributed



- Installed at El Centro, CA, Yuma, AZ and White Sands, NM
- Very low charge compressors at each case/unit cooler
- Two pound charge at each compressor
- Water loop for cooling with an exterior fluid cooler
- Potential for R-290/R-600 in future

Challenges of CO₂ Installation



- For remodels, a large load is required for start up
– at least 50%
- Coleman grade carbon dioxide (CO₂) refrigerant is not expensive. But, it may not be easily available. Recommend a 2nd full charge be available on site
- Extreme high pressure (XHP) rated pipe is hard to source

Adiabatic Gas Cooler/Condenser



- Standard coils with adiabatic pre-cooling media
- Runs dry during cold weather
- Objective: minimize time the system operates in transcritical mode

Experienced Partners Required



- Refrigeration manufactures are providing excellent support to installation crews
- Training is available from refrigeration and controls manufactures
- When you are the first installation in a geographic area, trained technicians may not be available for service

Opportunities



- Good public relations with customers – environmentally responsible
- Heat reclaim opportunities are excellent
- Refrigerant cost for service is low
- Future proof
- No reporting requirements for refrigerant usage



Comparison Study CO₂ Vs. Hydrofluorocarbon Refrigeration at DeCA Commissaries in Two Distinct Climate Regions

Four Locations



CA COMMISSARIES



NORTHEAST (NE) COMMISSARIES


Goal



Understand the performance of CO₂ refrigeration systems compared to hydrofluorocarbon (HFC) systems, using three parameters:

1. Energy efficiency ratio (EER) = Refrigeration load (BTU)/refrigeration power (W)
2. Maintenance effort
3. Carbon emissions

Energy Performance Parameter – CO₂ Commissary



$$\text{Total Refrigeration (MBH)} = \text{MBH (LT)} + \text{MBH (MT)}$$

$$\text{Total Refrigeration Electricity (kW-Ref)} = \text{kW(e-LT)} + \text{kW(e-MT)} + \text{kW(c-LT)} + \text{kW(c-MT)} + \text{kW(f)}$$

- kW(e) is electricity consumed in evaporator like evaporation fan, case lights, electronic expansion valve (EEV) defrost heaters & door & drain heaters
- kW(c) is electricity consumed in compressors
- kW(f) is electricity consumed in condenser fans

$$\text{Energy Efficiency Ratio (EER)} = \frac{\text{Total Refrigeration MBH}}{\text{Total Refrigeration kW}}$$

c-MT: Compressor Medium Temp

e-MT: Evap Medium Temp

F: Fahrenheit


kW: Kilowatt

LT: Low Temperature

MBH: Thousand British Thermal Units per hour


MT: Medium Temperature

Energy Performance Parameter – HFC Commissary



$$\text{Total Refrigeration (MBH)} = \text{MBH (LT)} + \text{MBH (MT)}$$

$$\text{Total Refrigeration Electricity (kW-Ref)} = kW(e-LT) + kW(e-MT) + kW(c-LT) + kW(c-MT) + kW(f-LT) + kW(f-MT)$$



- $kW(e)$ is electricity consumed in evaporator like evaporation fan, case lights, EEV valve defrost heaters & door & drain heaters
- $kW(c)$ is electricity consumed in compressors
- $kW(f)$ is electricity consumed in condenser fans

$$\text{Energy Efficiency Ratio (EER)} =$$

$$\frac{\text{Total Refrigeration MBH}}{\text{Total Refrigeration kW}}$$

System Comparison – CA Commissaries

Edward-CO2			
Suction Gr	Ckt#	Sat Suct T	MBH
CS1-LT	1-6	-16F	84.8
CS2-LT	7-11	-16F	72.9
	Total LT =		157.7
CS3-MT	12-24	+17F	276.4
CS4-MT	25-37	+17F	425.2
	Total MT =		701.6
Total Refg MBH			859.3

China-Lake-R407a				% Diff MBH
Suction Gr	Ckt#	Sat Suct T	MBH	
CS1-LT	1-8	-16F	82.5	
	Total LT =		82.5	-48%
CS2-MT	1-29	+18F	442.2	
	Total MT =		442.2	-37%
Total Refg MBH			524.7	-39%

Condenser Type =	BAC Trillium	Condenser Type =	BAC Trillium
Precool Temp	70F	Precool Temp	75F
WI Fan Motors	ECM	WI Fan Motors	ECM
WI Lights	T8/LED	WI Lights	T8/LED
Case Fan Motors	ECM	Case Fan Motors	ECM
CaseLights	Mostly LED	CaseLights	Mostly LED
Case Night Set backs	Yes (except 38 doors)	Case Night Set backs	Yes (except 12 doors)

BAC: Baltimore Aircoil Company
 Ckt: Circuits
 ECM: Electronically Commutated Motors
 Gr: Group
 Sat Suct T: Saturation temperature
 LED: Light-emitting Diode
 WI: Walk-ins
 VFD: Variable Frequency Drive

System Comparison – NE Commissaries

Newport-CO2			
Suction Gr	Ckt#	Sat Suct T	MBH
CS1-LT	1-12	-15F	170.5
	Total LT =		170.5
CS2-MT	14-28	+18F	151.9
CS3-MT	30-44	+24F	417
	Total MT =		568.9
Total Refg MBH			739.4

New London-R404a				% Diff
Suction Gr	Ckt#	Sat Suct T	MBH	MBH
CS1-LT	1-6	-22F	122.3	
CS2-LT	21-26	-13F	58.5	
CS2S-LT		-13F	52	
	Total LT =		180.8	6%
CS3-MT	31-43	+18F	295	
CS3S-MT		+18F	63	
CS4-MT	51-62	+26F	431.7	
CS4S-MT		+16F	63	
	Total MT =		852.7	50%
Total Refg MBH			1034	40%

Condenser Type =	BAC Trillium	Condenser Type =	Hussmann Air Cooled with VFD
Precool Temp	73F	Precool Temp	Not Applicable

WI Fan Motors	ECM	WI Fan Motors	ECM
WI Lights	T8/LED	WI Lights	T8/LED

Case Fan Motors	ECM	Case Fan Motors	ECM
Case Lights	Mostly LED	Case Lights	Mostly LED
Case Night Set backs	No (always ON)	Case Night Set backs	Yes (except 12 doors)


Power Measurements




Total Refrigeration



Transformer Load (XTMR)



Net Refrigeration



—

=

Energy Comparison – Monthly Trend



EDWARDS - CO2

Month	OAT	Total Refg kW	XFMR kW	Net Refg kW	EER Total Refg	EER Net
Mar	51.6	74.0	0.0		11.8	
Apr	60.8	80.1	17.6	62.5	10.9	14.5
May	71.7	84.3	30.3	54.0	10.3	16.2
Jun	77.9	87.6	30.4	57.2	9.9	15.4
Jul	84.2	90.2	30.0	60.2	9.6	14.6
Aug	85.7	99.8	31.2	68.6	8.8	12.9
Sep	77.6	89.6	30.1	59.5	9.8	14.9
Oct						
Avg	72.6	86.4	24.0	62.4	10.2	14.3

CHINA LAKE - R407a

Month	OAT	Total Refg kW	XFMR kW	Net Refg kW	EER Total Refg	EER Net
Mar						
Apr	76.2	37.9	12.0	25.9	14.6	22.1
May	80.1	39.7	11.6	28.1	13.7	19.7
Jun	86.3	40.1	10.8	29.3	13.3	18.4
Jul	92.9	41.4	10.9	30.4	12.8	17.6
Aug	93.7	44.3	11.2	33.1	12.0	16.1
Sep	86.6	40.7	11.1	29.6	13.2	18.6
Oct						
Avg	87.0	41.0	11.2	29.8	13.1	18.4

NEWPORT - CO2

Month	OAT	Total Refg kW	XFMR kW	Net Refg kW	EER Total Refg	EER Net
Mar	44.8	72.3	0.0		10.2	
Apr	46.6	74.1	12.3	61.5	10.0	13.8
May	57.2	81.3	39.0	42.2	9.2	18.3
Jun	69.1	91.6	39.4	52.1	8.1	14.7
Jul	75.9	102.4	39.9	62.4	7.3	12.3
Aug	75.0	104.8	40.0	64.7	7.1	11.9
Sep	68.2	94.1	39.7	54.3	7.9	14.2
Oct	63.1	97.9	39.2	58.6	7.7	13.4
Avg	62.5	89.0	30.4	58.4	8.5	13.7

NEWLONDON - R404a


Month	OAT	Total Refg kW	XFMR kW	Net Refg kW	EER Total Refg	EER Net
Mar	45.1	84.5	0.0		12.4	
Apr	47.7	91.9	12.6	79.3	11.7	15.3
May	60.1	98.5	45.4	53.1	10.7	20.6
Jun	72.4	107.9	46.9	61.0	9.7	17.9
Jul	79.1	117.0	48.5	68.5	9.0	15.8
Aug	76.7	113.1	47.7	65.4	9.3	16.7
Sep	67.4	105.1	48.5	56.7	10.0	19.4
Oct	59.5	100.6	49.2	51.4	10.4	21.5
Avg	65.8	104.3	39.5	64.8	10.2	17.4

Mostly Summer Months


Energy Comparison – Monthly Trend




Total Refrigeration (Avg kW)




Net Refrigeration (Avg kW)







Total EER (BTU/W)




Net EER (BTU/W)



Weather Normalized – Net Refrigeration



Weather Normalized



OAT	Edwards-CO2	China-R407a	NewPort-CO2	NewLondon-R404a
40	20.5	30.1	25.4	27.4
50	18.9	26.9	20.7	23.9
60	17.5	24.1	16.8	20.7
70	16.1	21.6	13.6	17.9
80	14.8	19.5	11.1	15.4
90	13.6	17.7	9.3	13.2
100	12.5	16.2	8.3	11.3

Maintenance Summary



Store Name	# of Refrigeration Issues
EDWARDS – CO ₂ (Jan-May 2020)	4
CHINA LAKE – R407A (Jan-May 2020)	9
NEW-PORT – CO ₂ (Jan-Sept 2020)	15
NEW LONDON – R404A (Jan-Sept 2020)	13

Maintenance Needs Are Similar



Equivalent 1000MBH Store

Bin Analysis Using Weather Model Generated

OAT	BIN Hrs	Edwards-CO2			China Lake-R407a			
		EER	Refg kW	Refg kWh-(1000MBH)	EER	Refg kW	Refg kWh-(1000MBH)	
112.5	19	11.3	88.8	1687.0	14.8	67.4	1280.2	
107.5	69	11.7	85.2	5880.5	15.3	65.3	4503.9	
102.5	275	12.2	81.8	22486.4	15.9	63.0	17312.9	
97.5	398	12.8	78.4	31214.2	16.5	60.5	24072.9	
92.5	335	13.3	75.2	25194.4	17.3	57.9	19401.0	
87.5	492	13.9	72.1	35478.3	18.1	55.3	27203.2	
82.5	598	14.5	69.1	41345.1	19.0	52.7	31490.1	
77.5	667	15.1	66.3	44217.2	20.0	50.1	33384.8	
72.5	615	15.7	63.6	39095.7	21.1	47.5	29211.8	
67.5	700	16.4	61.0	42678.7	22.2	45.0	31514.3	
62.5	798	17.1	58.5	46673.1	23.5	42.6	34021.0	
57.5	722	17.8	56.1	40519.4	24.8	40.3	29130.4	
52.5	779	18.6	53.9	41961.5	26.2	38.2	29733.8	
47.5	656	19.3	51.7	33927.0	27.7	36.1	23683.9	
42.5	649	20.1	49.7	32237.8	29.3	34.2	22163.7	
37.5	472	21.0	47.7	22527.0	31.0	32.3	15249.8	
32.5	286	21.8	45.9	13120.1	32.7	30.6	8744.8	
27.5	133	22.7	44.1	5866.9	34.5	28.9	3850.1	
22.5	68	23.6	42.4	2885.6	36.5	27.4	1864.6	
17.5	29	24.5	40.8	1184.3	38.5	26.0	753.7	
		Total Annual kWh=			530,180	Total Annual kWh=		388,571

Annual Energy Difference= 141,609 (CO2 Store is higher)

GWP Analysis



ENERGY DIFFERENCE:

Annual Energy Difference= 141,609 (CO2 Store is higher)

lbs of CO2 per kWh (EIA Source)= 0.99
lbs of CO2 (GWP) due to higher kWh = 140,193

REFRIGERANT LEAK EFFECT:

lbs of R407a in China Lake = 1400 (524 MBH REFRIGERATION)
Normalized 1000 MBH Refg lbs of R407a required = 2672
Annual Leak rate of 20% = 534
lbs of CO2 per lb of R407a (EIA Source)= 2100
Total equivalent lbs of CO2 = 1,122,137 (HFC STORE IS HIGHER)

Net GWP of HFC store higher than Transcrital CO2 store (estimated) = 981,944

Summary



- Energy
 - HFC stores performed better by almost 28-30%
- Maintenance
 - They seem to have similar maintenance needs
- GWP
 - CO₂ store has significantly lower GWP (even when higher energy is factored in)

What Now?



- Continue the study through the winter to capture a full year's worth of operation. Expecting CO₂ systems to perform better in the winter months.
- Both CO₂ systems could be fine tuned to perform better. Condenser not running optimally.



Contacts and Additional Information

Contact Information

- John Stuit, DeCA
john.stuit@deca.mil
- Abtar Singh, Singh360 Engineers
abtar@singh360.com
- John Post, Singh360 Engineers
jpost@singh360.com

GreenChill Contact Information

- Kirsten Cappel, U.S. EPA
202.343.9556
cappel.kirsten@epa.gov

Upcoming Webinars

Date	Webinar Topic
12/8	Small and Independent Grocers Partnering with GreenChill

Join our webinar invitation list or request today's slides: EPA-GreenChill@abtassoc.com

View past GreenChill webinars: www.epa.gov/greenchill/events-and-webinars